

| DATE       | PRODUCER   | CUSTOMER | PRODUCT                                                   |
|------------|------------|----------|-----------------------------------------------------------|
| 16/10/2024 | R.E.M. SRL | SORGENIA | ABB13MAG10AH001 MATRICOLA<br>N°3GC105002592760010001 UVW2 |

RESISTANCE TEST

|         | R min | R max | R       | Temperature | Result | max dR % | dR % | Result dR |
|---------|-------|-------|---------|-------------|--------|----------|------|-----------|
| Phase 1 | 0     | 99999 | 0.04783 | 21.93       | PASS   | 7.7      | 0.2  | PASS      |
| Phase 2 |       |       | 0.04774 |             | PASS   |          |      |           |
| Phase 3 |       |       | 0.04773 |             | PASS   |          |      |           |

SURGE TEST

|  | V | Toll% L | L | dL % | Toll% Q | Q | dQ % | Result | T Q F % |
|--|---|---------|---|------|---------|---|------|--------|---------|
|  |   |         |   |      |         |   |      |        |         |
|  |   |         |   |      |         |   |      |        |         |
|  |   |         |   |      |         |   |      |        |         |
|  |   |         |   |      |         |   |      |        |         |

H. V. TEST

|  | V (V) | I Max (A) | I Meas(A) | Result |
|--|-------|-----------|-----------|--------|
|  | 1066  | 0.004     | 2         | GO     |

MEGAOHMETER TEST

|  | V (V) | R Min [MOhm] | R Meas [MOhm] | Result |
|--|-------|--------------|---------------|--------|
|  | 1067  | 1000         | 5             | GO     |

SURGE 1.2/50 TEST

|  | V PK (V) | V 50u | Result |
|--|----------|-------|--------|
|  | 771      | 428   | GO     |

POLARIZATION INDEX TEST

|  | V PK (V) | Ri | Rf | K | Time (s) |
|--|----------|----|----|---|----------|
|  |          |    |    |   |          |

