

DATE	PRODUCER	CUSTOMER	PRODUCT
15/10/2024	R.E.M. SRL	SORGENIA	ABB13MAG50AH006 MATRICOLA N°3GC10500259276001025 UVW2

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.04318	24.2	PASS	7.7	0.3	PASS
Phase 2			0.04333		PASS			
Phase 3			0.04327		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1042	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

