

DATE

22/06/2020

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

ROTORE ECCITATRICE Generatore
ABBAMG500L8 N°Comm 2020-0274

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.04565	24.06	PASS	6.3	0.1	PASS
Phase 2			0.04571		PASS			
Phase 3			0.0457		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	564	4	587.6 u	0.2	10.9	27.27	1.8	GO	98
Phase 2	564		587.6 u			27.27		GO	
Phase 3	564		586.1 u			27.78		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	686.2	0	1	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	686.2	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	557	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

