

DATE

25/06/2020

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN S.C.R.L.

PRODUCT

GENERATORE ABB AMG500L8
N°Comm 2020-0274

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.00129	20.15	PASS	6.3	1	PASS
Phase 2			0.00129		PASS			
Phase 3			0.0013		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	578	4	60.95 u	1.6	10.9	12.12	1.5	GO	96.9
Phase 2	571		59.96 u			11.94		GO	
Phase 3	578		60.45 u			11.94		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1041	0.004	0.284	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	500	357	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

