

DATE

22/08/2019

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A

PRODUCT

FELM Y2V400L N°Comm 2019-0573

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00284	25.4	PASS	5	0.8	PASS
Phase 2			0.00287		PASS			
Phase 3			0.00284		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1057	4	372.0 u	0.6	8.9	30.91	0	GO	99.4
Phase 2	1042		372.0 u			30.91		GO	
Phase 3	1057		374.3 u			30.91		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1042	0	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1029	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	500	285	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

