

DATE

13/11/2019

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI BARLETTA

PRODUCT

ROTORE ANSALDO E1Z3572LB 4
N_762273 N_Comm 2019 0808

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01119	15.22	PASS	5	0.2	PASS
Phase 2			0.01122		PASS			
Phase 3			0.01122		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	828	4	944.5 u	0	8.9	28.21	2.6	GO	97.4
Phase 2	814		944.5 u			28.95		GO	
Phase 3	828		944.5 u			28.21		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1035	0.003	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1034	814.89	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	589	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

