

DATE

28/08/2019

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM GUIDONIA

PRODUCT

ROTORE SAVIGLIANO DOPO
VERNICIATURA VCOMM 20190564

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00919	24.55	PASS	5	1.7	PASS
Phase 2			0.00934		PASS			
Phase 3			0.00932		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	585	4	1.801 m	1	8.9	81.48	3.6	GO	95.4
Phase 2	585		1.783 m			78.57		GO	
Phase 3	585		1.783 m			81.48		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1092	442.4	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	492	257	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

