

DATE

28/08/2019

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM GUIDONIA

PRODUCT

SATORE SAVIGLIANO COMM 2019
0564

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.10484	25.62	PASS	5	0.4	PASS
Phase 2			0.10522		PASS			
Phase 3			0.10501		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	2964	4	39.93 m	0.4	8.9	55.26	0	GO	99.6
Phase 2	3000		39.88 m			55.26		GO	
Phase 3	3000		40.05 m			55.26		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	3557	0.004	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	3545	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

