

DATE

29/08/2019

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM GUIDONIA

PRODUCT

commessa 20190565

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00526	26.02	PASS	5	15.7	FAIL
Phase 2			0.00606		PASS			
Phase 3			0.00608		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	610	4	1.582 m	0.6	8.9	71.79	3.4	GO	96
Phase 2	610		1.587 m			71.79		GO	
Phase 3	610		1.592 m			74.36		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	535	267	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

