

DATE

05/06/2019

PRODUCER

R.E.M. SRL

CUSTOMER

CEMP S.R.L.

PRODUCT

CEMP AB70 225M4 3 EXD
N°1407725005y14 Comm2019_0083

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.09	21.48	PASS	5	0.3	PASS
Phase 2			0.0897		PASS			
Phase 3			0.08999		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1371	4	2.328 m	0.5	8.9	54.17	2	GO	97.5
Phase 2	1371		2.334 m			54.17		GO	
Phase 3	1371		2.340 m			53.06		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

