

DATE

23/09/2020

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

MARELLI NVT400S6 N. 806149
Comm 2020 0306

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.0193	22.2	PASS	6.3	2	PASS
Phase 2			0.01928		PASS			
Phase 3			0.01892		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1039	4	707.8 u	0.4	10.9	32.88	2.8	GO	96.8
Phase 2	1039		709.4 u			31.94		GO	
Phase 3	1039		706.3 u			32.88		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	678	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

