

DATE

28/08/2020

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI Barletta

PRODUCT

Indotto Ansaldo PMFZ 355LB4
N°COMM 2020 0554

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.01166	25.13	PASS	6.3	0	PASS
Phase 2			0.01166		PASS			
Phase 3			0.01166		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	785	4	1.097 m	0.7	10.9	36.84	2.6	GO	96.7
Phase 2	800		1.105 m			37.84		GO	
Phase 3	785		1.105 m			36.84		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	258.1	1.681	1.288	NO GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	370.5	5	5	NO GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	428	214	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

