

DATE

28/08/2020

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI Barletta

PRODUCT

Statore Ansaldo PMFZ 355LB4
N°Comm 2020 0554

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.00399	26.28	PASS	6.3	1.8	PASS
Phase 2			0.00406		PASS			
Phase 3			0.00406		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	914	4	199.5 u	0.9	10.9	23.26	2.3	GO	96.8
Phase 2	900		201.2 u			23.81		GO	
Phase 3	914		199.5 u			23.26		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	812.8	0.171	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	797.2	5	5	NO GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	535	285	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

