

DATE

16/09/2020

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO

PRODUCT

Rotore WEGMAF6300 N°121438 09
03 N°Comm 2020-0600

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.09933	28.02	PASS	6.3	0.2	PASS
Phase 2			0.09931		PASS			
Phase 3			0.09912		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1066	0.004	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

