

DATE

16/09/2020

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM (Barletta)

PRODUCT

Statore WEGMAF6300 N°121438 09
03 N°Comm 2020-0600

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0.1	2	0.12831	29.13	PASS	6.3	0	PASS
Phase 2			0.12831		PASS			
Phase 3			0.12833		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3785	4	851.4 m	0.3	10.9	194.4	2.9	GO	96.8
Phase 2	3750		854.0 m			188.9		GO	
Phase 3	3750		853.9 m			188.9		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5107	0.004	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5133	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

