

DATE

21/10/2020

PRODUCER

R.E.M. SRL

CUSTOMER

CONSORZIO DI BONIFICA

PRODUCT

Rotore TECNOMASIO MVRP2616
N°Comm 2020 0493

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.05736	15.31	PASS	6.3	0.5	PASS
Phase 2			0.05756		PASS			
Phase 3			0.05766		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1228	4	1.780 m	0.1	10.9	46.67	0	GO	99.9
Phase 2	1228		1.780 m			46.67		GO	
Phase 3	1228		1.783 m			46.67		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1104	0.004	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1007	514	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

