

DATE

16/07/2020

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT10PGC11AP001 ABB Tp
M3BB315MLA4 N°3GF10029785**RESISTANCE TEST**

| | R min | R max | R | Temperature | Result | max dR % | dR % | Result dR |
|---------|-------|--------|---------|-------------|--------|----------|------|-----------|
| Phase 1 | 0 | 999999 | 0.01673 | 25.66 | PASS | 6.3 | 1.4 | PASS |
| Phase 2 | | | 0.01697 | | PASS | | | |
| Phase 3 | | | 0.0168 | | PASS | | | |

SURGE TEST

| | V | Toll% L | L | dL % | Toll% Q | Q | dQ % | Result | T Q F % |
|--|---|---------|---|------|---------|---|------|--------|---------|
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

H. V. TEST

| | V (V) | I Max (A) | I Meas(A) | Result |
|--|-------|-----------|-----------|--------|
| | 1067 | 0 | 1.1 | GO |

MEGAOHMMETER TEST

| | V (V) | R Min [MOhm] | R Meas [MOhm] | Result |
|--|-------|--------------|---------------|--------|
| | 1067 | 1000 | 5 | GO |

SURGE 1.2/50 TEST

| | V PK (V) | V 50u | Result |
|--|----------|-------|--------|
| | 464 | 321 | GO |

POLARIZATION INDEX TEST

| | V PK (V) | Ri | Rf | K | Time (s) |
|--|----------|----|----|---|----------|
| | | | | | |

