

**DATE**

14/07/2020

**PRODUCER**

R.E.M. SRL

**CUSTOMER**

SORGENIA

**PRODUCT**

ABB13MAG50AH004 MATRICOLA  
N°3GC10500259276001028 UVW1

**RESISTANCE TEST**

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.15881	24.91	PASS	6.3	0.1	PASS
Phase 2			0.15881		PASS			
Phase 3			0.15862		PASS			

**SURGE TEST**

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

**H. V. TEST**

	V (V)	I Max (A)	I Meas(A)	Result
	1017	0	1.1	GO

**MEGAOHMMETER TEST**

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1004	1000	5	GO

**SURGE 1.2/50 TEST**

	V PK (V)	V 50u	Result
	785	428	GO

**POLARIZATION INDEX TEST**

	V PK (V)	Ri	Rf	K	Time (s)

