

DATE

23/09/2020

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT

ANSALDO CT 400Y2 N 123703
Comm 2020 0606

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.76757	22.2	PASS	6.3	0.1	PASS
Phase 2			0.76757		PASS			
Phase 3			0.76853		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4767	4	135.4 m	0.6	10.9	73.85	2.1	GO	97.3
Phase 2	4767		136.1 m			72.31		GO	
Phase 3	4714		136.2 m			73.44		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5197	0	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5146	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

