

DATE

07/05/2020

PRODUCER

TEFIN

CUSTOMER

PRODUCT

STATORE GENERATORE ABB
AMG500L8

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.04	25.4	PASS	6.3	114.8	FAIL
Phase 2			0.08594		PASS			
Phase 3			0.04833		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	185	4	135.8 u	100	10.9	20.83	100	GO	0
Phase 2	42		0.000 u			0		NO GO	
Phase 3	42		0.000 u			0		NO GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	0	1.422	0.1	NO GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	0	5	5	NO GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

