

DATE

21/07/2020

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

STATORE ALTERNATORE N°REM
15070 N°Comm 2020-0451

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.00347	26.68	PASS	6.3	1.7	PASS
Phase 2			0.00353		PASS			
Phase 3			0.0035		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	782	4	234.3 u	1.2	10.9	32.76	1.7	GO	97.1
Phase 2	782		237.1 u			32.76		GO	
Phase 3	782		236.1 u			33.33		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1002	0.004	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1016	320.2	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	464	285	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

