

DATE

12/08/2020

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

ROTORE ECCITATRICE N°Comm
2020-0502

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.04096	23.88	PASS	6.3	0.2	PASS
Phase 2			0.04091		PASS			
Phase 3			0.04087		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1103	4	484.9 u	0.8	10.9	25.71	0	GO	99.2
Phase 2	1114		482.3 u			25.71		GO	
Phase 3	1103		486.2 u			25.71		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1067	0	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

