

DATE

30/10/2018

PRODUCER

R.E.M. SRL

CUSTOMER

CONSORCIO BONIFICA

PRODUCT

Statore CGE TNAU375-565
N°324548 N°Comm 2016-0956

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.01763	17.4	PASS	5	0.4	PASS
Phase 2			0.01767		PASS			
Phase 3			0.0176		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	821	5.2	1.788 m	1.9	12.3	57.58	1.5	GO	96.6
Phase 2	828		1.801 m			56.72		GO	
Phase 3	885		1.824 m			57.35		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	1.088	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	571	214	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

