

DATE

30/01/2018

PRODUCER

R.E.M. SRL

CUSTOMER

SINIAT

PRODUCT

Siemens Rem13683
1LG6258_2AA99_250M

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0623	9.931	PASS	18.5	3.7	PASS
Phase 2			0.06289		PASS			
Phase 3			0.06066		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1864		1.849 m			50.79		NO GO	
Phase 2	1864		1.816 m			53.13		NO GO	
Phase 3	1864		1.844 m			51.56		NO GO	
Sample									

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	2006	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	2021	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

